




Product data sheet (in accordance with EU regulation no. 811/2013,)

1	Brand name	Hermann Saunier Duval						
2	Models	I	ThemaFAST 4 Condensing 26-A (H-IT)					
		II	THEMACONDENS 26-A (P-IT)					
		III	Thema Condens 26 -A (H-IT)					
		IV	Thema Condens 30 -A (H-IT)					
		V	Thema Condens 26 -A-H (H-IT)					
		VI	-					

			I	II	III	IV	V	VI
3	Temperature application		Medium/Low	Medium/Low	Medium/Low	Medium/Low	Medium/Low	-
4	Hot water generation: Specified load profile		XL	XL	XL	XL	XL	-
5	Room heating: Seasonal energy-efficiency class		A	A	A	A	A	-
6	Hot water generation: Energy-efficiency class		A	A	A	A	A	-
7	Room heating: Nominal heat output(*8) (*11)	P_{rated} kW	24	24	24	24	24	-
8	Annual energy consumption(*8)	Q_{HE} kWh	11274	11274	11274	20943	11274	-
9	Annual electricity consumption(*8)	AEC kWh	182	36	36	38	36	-
10	Annual fuel consumption(*8)	AFC GJ	17	17	17	17	17	-
11	Room heating: Seasonal energy efficiency(*8)	η_s %	94	94	94	93	94	-
12	Hot water generation: Energy efficiency(*8)	η_{WH} %	81	86	86	86	86	-
13	Sound power level, indoor	$L_{WA indoor}$ dB(A)	50	50	50	51	50	-
14	Option to only operate during low-demand periods.		-	-	-	-	-	-
15	 All specific precautions for assembly, installation and maintenance are described in the operating and installation instructions. Read and follow the operating and installation instructions.							
16	 "smart" value "1": The information on the hot water generation energy efficiency and on the annual power or fuel consumption applies only when the intelligent control system is switched on.							
17	 All of the data that is included in the product information was determined by applying the specifications of the relevant European directives. Differences to product information listed elsewhere may result in different test conditions. Only the data that is contained in this product information is applicable and valid.							


(*8) For average climatic conditions

(*11) For boilers and combination boilers with a heat pump, the nominal heat output "Prated" is the same as the design load in heating mode "Pdesignh", and the nominal heat output for an auxiliary boiler "Psup" is the same as the additional heating output "sup(Tj)"



Product information (in accordance with EU regulation no. 813/2013,)

1	Brand name		Hermann Saunier Duval
2	Models	I	ThemaFAST 4 Condensing 26-A (H-IT)
		II	THEMACONDENS 26-A (P-IT)
		III	Thema Condens 26 -A (H-IT)
		IV	Thema Condens 30 -A (H-IT)
		V	Thema Condens 26 -A-H (H-IT)
		VI	-

				I	II	III	IV	V	VI
18	Condensing boiler			✓	✓	✓	✓	✓	-
19	Low-temperature boiler(*2)			✓	✓	✓	✓	✓	-
20	B1 boiler			-	-	-	-	-	-
21	Room boiler with combined heat and power			-	-	-	-	-	-
22	Auxiliary boiler			-	-	-	-	-	-
23	Combination boiler			✓	✓	✓	✓	✓	-
24	Room heating: Nominal heat output(*11)	P_{rated}	<i>kW</i>	24	24	24	24	24	-
25	Usable heat output at nominal heat output and high-temperature operation(*1)	P_4	<i>kW</i>	24,2	24,2	24,2	24,4	24,2	-
26	Usable heat output at 30% of the nominal heat output and low-temperature operation	P_1	<i>kW</i>	8,0	8,0	8,0	8,2	8,0	-
27	Room heating: Seasonal energy efficiency	η_s	%	94	94	94	93	94	-
28	Efficiency for nominal heat output and high-temperature application(*4)	η_4	%	89,1	89,1	89,1	88,0	89,1	-
29	Efficiency at 30% of the nominal heat output and low-temperature application(*5)	η_1	%	98,5	98,5	98,5	98,4	98,5	-
30	Auxiliary power consumption: Full load	e_{max}	<i>kW</i>	0,041	0,041	0,041	0,035	0,041	-
31	Auxiliary power consumption: Partial load	e_{min}	<i>kW</i>	0,013	0,013	0,013	0,013	0,013	-
32	Power consumption: Standby-mode	P_{SB}	<i>kW</i>	0,003	0,003	0,003	0,003	0,003	-
33	Heat loss: Standby	P_{stby}	<i>kW</i>	0,042	0,042	0,042	0,042	0,042	-
34	Ignition flame energy consumption	P_{gn}	<i>kW</i>	0,000	0,000	0,000	-	0,000	-
35	Nitrogen oxide emissions	NO_x	<i>mg/kWh</i>	38	38	38	39	38	-
36	Hot water generation: Specified load profile			XL	XL	XL	XL	XL	-
37	Hot water generation: Energy efficiency	η_{WH}	%	81	86	86	86	86	-
38	Daily electricity consumption	Q_{elec}	<i>kWh</i>	0,841	0,165	0,165	0,175	0,165	-
39	Daily fuel consumption	Q_{fuel} <i>average</i>	<i>kWh</i>	22,135	22,429	22,429	22,462	22,429	-
40	Manufacturer			Hermann Saunier Duval					
41	Manufacturer's address			Vaillant Group Italia S.p.A Via Benigno Crespi, 70 20159 Milano Italy					
42	 All specific precautions for assembly, installation and maintenance are described in the operating and installation instructions. Read and follow the operating and installation instructions.								

(*1) High-temperature operation means a return temperature of 60 °C at the boiler inlet and a flow temperature of 80 °C at the boiler outlet.




(*2) Low-temperature operation means a return temperature (at the boiler inlet) of 30 °C for the floor-standing condensing boiler, of 37 °C for a low-temperature floor-standing boiler and of 50 °C for other boilers.

(*4) High-temperature operation means a return temperature of 60 °C at the boiler inlet and a flow temperature of 80 °C at the boiler outlet.

(*5) Low-temperature operation means a return temperature (at the boiler inlet) of 30 °C for the floor-standing condensing boiler, of 37 °C for a low-temperature floor-standing boiler and of 50 °C for other boilers.

(*11) For boilers and combination boilers with a heat pump, the nominal heat output "Prated" is the same as the design load in heating mode "Pdesignh", and the nominal heat output for an auxiliary boiler "Psup" is the same as the additional heating output "sup(Tj)"



43		This floor-standing boiler with natural draught must only be connected to a flue gas installation assigned to one of several dwellings in existing buildings. The flue gas installation directs combustion residues from the installation room into the open air. It draws the combustion air directly from the installation room and is equipped with an atmospheric sensing device. Due to low efficiency, you must avoid using this floor-standing boiler for any other purposes – it would lead to higher energy consumption and higher operating costs.							
44		Read and follow the operating and installation instructions regarding assembly, installation, maintenance, removal, recycling and/or disposal.							
45		All of the data that is included in the product information was determined by applying the specifications of the relevant European directives. Differences to product information listed elsewhere may result in different test conditions. Only the data that is contained in this product information is applicable and valid.							
46	Weekly power consumption with an intelligent control system	$Q_{elec, week, smart}$	kWh	-	-	-	-	-	-
47	Weekly power consumption without an intelligent control system	$Q_{elec, week}$	kWh	-	-	-	-	-	-
48	Weekly fuel consumption with an intelligent control system	$Q_{fuel, week, smart}$	kWh	-	-	-	-	-	-
49	Weekly fuel consumption without an intelligent control system	$Q_{fuel, week}$	kWh	-	-	-	-	-	-
50	Nominal heat output for auxiliary heating	P_{sup}	kW	-	-	-	-	-	-
51	Type of energy input for the auxiliary boiler		0	-	-	-	-	-	-

(*1) High-temperature operation means a return temperature of 60 °C at the boiler inlet and a flow temperature of 80 °C at the boiler outlet.

(*2) Low-temperature operation means a return temperature (at the boiler inlet) of 30 °C for the floor-standing condensing boiler, of 37 °C for a low-temperature floor-standing boiler and of 50 °C for other boilers.

(*4) High-temperature operation means a return temperature of 60 °C at the boiler inlet and a flow temperature of 80 °C at the boiler outlet.

(*5) Low-temperature operation means a return temperature (at the boiler inlet) of 30 °C for the floor-standing condensing boiler, of 37 °C for a low-temperature floor-standing boiler and of 50 °C for other boilers.

(*11) For boilers and combination boilers with a heat pump, the nominal heat output "Prated" is the same as the design load in heating mode "Pdesignh", and the nominal heat output for an auxiliary boiler "Psup" is the same as the additional heating output "sup(Tj)"

